

ECONOMIC EVALUATION OF PV MICROGRID

BY Ganesh N. Jadhav SAP ID:500049574

GUIDED BY Dr.Mohan P. Thakre

Assistant Professor in Electrical Engineering
K.K. Wagh Institute of Engineering Education and Research, Nashik,
Maharashtra, India 422003

A DISSERTATION REPORT SUBMITTED IN PARTIAL FULFILLMENT OF THE REQUIREMENTS FOR

MBA (POWER MANAGEMENT)

CENTRE FOR CONTINUING EDUCATION

UNIVERSITY OF PETROLEUM & ENERGY STUDIES, DEHRADUN

Dec 2019

Acknowledgements

This is to acknowledge with thanks the help, guidance and support that I have received during the Dissertation.

I have no words to express a deep sense of gratitude to the management of K.K. Wagh Institute of Engineering Education and Research, Nashik for giving me an opportunity to pursue my Dissertation, and in particular Prof. Dr. Mohan P. Thakare, for his able guidance and support.

I must also thank Prof. Omkar N Buwa and Mr. Sanjay T. Kawale for his valuable support.

I also place on record my appreciation of the support provided by Library staff of KKWIEER, Nashik.

Ganesh N. Jadhav

Flat No 16, Gokuldham Residency Apartment, Audumbar Nagar, Amrutdham, Panchwati, Nashik 422003





K. K. Wagh Institute of Engineering Education & Research

Declaration by the Guide

This is to certify that Mr. Ganesh Nandkumar Jadhav, a student of MBA (Power Management), SAP ID 500049574 of UPES has successfully completed this dissertation report on "Economic Evaluation of PV Mrcrogrid" under my supervision.

Further, I certify that the work is based on the investigation made, data collected and analyzed by him and it has not been submitted in any other University or Institution for award of any degree. In my opinion it is fully adequate, in scope and utility, as a dissertation towards partial fulfillment for the award of degree of Master of Business Administration (MBA) (Power Management).

Dr. Mohan P. Thakre

Assistant Professor in Electrical Engineering

K.K. Wagh Institute of Engineering Education and Research, Nashik

Nashik, Maharashtra, India 422003

Mobile: 9730291951 e-mail: mpthakre@kkwagh.edu.in

Date:30/12/2019

Place: Nashik

Contents

| ckno | owledgements | ii |
|--------|--|---|
| ertifi | icate | iii |
| able | of Contents | iv |
| st of | f Figures v | rii |
| st of | Tables vi | iii |
| bstra | act | ix |
| Inti | roduction | 1 |
| 1.1 | Overview of Power Sector | 1 |
| 1.2 | Background | 2 |
| | 1.2.1 Perspective of National Electricity Policy | 2 |
| | 1.2.2 Tariff Policy 2016 | 3 |
| | 1.2.3 Grid Connected Rooftop Solar Program | 4 |
| 1.3 | Need for Research | 5 |
| 1.4 | Research Hypothesis | 6 |
| Lite | erature Review | 7 |
| 2.1 | Introduction | 7 |
| | ertificable st of st of bstra 1.1 1.2 | st of Figures st of Tables vi bstract Introduction 1.1 Overview of Power Sector 1.2 Background 1.2.1 Perspective of National Electricity Policy 1.2.2 Tariff Policy 2016 1.2.3 Grid Connected Rooftop Solar Program 1.3 Need for Research 1.4 Research Hypothesis Literature Review |

| | | 2.1.1 | Microgrid Power System (Broad area) | 7 |
|---|------|---------|---|------------|
| | | 2.1.2 | Renewable energy in Microgrid and challenges (Broad area) | 8 |
| | | 2.1.3 | Solar rooftop design and implementation (Narrow area) | 8 |
| | | 2.1.4 | Economic evaluation using different indices(Narrow area) | S |
| | 2.2 | Factor | Critical to Success of Study | ç |
| | 2.3 | Summ | ary | 10 |
| 3 | Res | earch | Design, Methodology and Plan | 12 |
| | 3.1 | Introd | luction | 12 |
| | 3.2 | Resear | rch Plan | 12 |
| | 3.3 | Histor | ical Development of Renewable Energy Technology | 13 |
| | | 3.3.1 | Global Review | 13 |
| | | 3.3.2 | National Review | 15 |
| | 3.4 | Input | Data for Calculation of Levelized Cost of Fnergy(LCOE) | 17 |
| | | 3.4.1 | Size and cost of solar PV system | 17 |
| | | 3.4.2 | Cost of energy from grid | 18 |
| | | 3.4.3 | Load Profile | 18 |
| | 3.5 | Levelia | zed Cost of Energy (LCOE) | 20 |
| | | 3.5.1 | Calculation of LCOE | 20 |
| | | 3.5.2 | Annualized Cost | 21 |
| | | 3.5.3 | Net Present Cost (NPC) | 22 |
| | | 3.5.4 | Annual Real Discount Rate | 22 |
| | | 3.5.5 | Capital Recovery Factor | 22 |
| | 3.6 | Site Se | election | 23 |
| | 3.7 | Procee | dure Followed for Economic Evaluation of solar rooftop PV | 23 |
| | | | | |
| 1 | Syst | | escription, Result and Analysis | 2 4 |
| | 4.1 | | n Description: Case-I Residential Project | 24 |
| | 4.2 | Systen | Description: Case-II Commercial Project | 32 |
| | 4.3 | Result | :Case-I Residential Project | 40 |

| | 4.4 | Result: | Case-II | Commercial | Project . | • • • • • | | 55 |
|--------------|--------|----------|---------|------------|-----------|-----------|------|--------|
| 5 | Con | nclusion | | | | | | 71 |
| \mathbf{R} | efere: | nces | | | | | | 73 |

List of Figures

| 3.1 | Global renewable energy consumption | 14 |
|-----|--|----|
| 3.2 | Solar energy generation by region | 15 |
| 3.3 | Installed grid power capacity from all sources in India as of 30 June 2019 | 16 |
| 3.4 | Installed grid interactive renewable power capacity in India as of 30 June | |
| | 2019 (excluding large hydro) | 16 |
| 3.5 | Daily load curve (Residential) | 19 |
| 3.6 | Yearly load curve (Residential) | 19 |
| 3.7 | Daily load curve (commercial) | 19 |
| 3.8 | Yearly load curve (commercial) | 20 |

List of Tables

| 3.1 | Size and cost of solar PV system | 17 |
|-----|---|----|
| 3.2 | Cost of energy from grid | 18 |
| 3.3 | Load Profile | 18 |
| 4.1 | Different cases for which simulations are carried out Y: Feasible N: Not | |
| | Feasible | 40 |
| 4.2 | Levelized cost of energy (LCOE) for case-I | 53 |
| 4.3 | ROI, IRR and PBP for different configuration and sell back rate case-I $$. | 54 |
| 4.4 | CO2 emission for different capacity of solar PV | 54 |
| 4.5 | Different cases for which simulations are carried out Y: Feasible N: Not | |
| | Feasible | 55 |
| 4.6 | Levelized cost of energy (LCOE) for case-II | 68 |
| 4.7 | ROI, IRR and PBP for different configuration and sell back rate case-II . | 69 |
| 4.8 | CO2 emission for different capacity of solar PV | 70 |
| | | |

Abstract

Solar photovoltaic (PV) power systems for both utility as well as roof mount applications growing rapidly in India. Solar power plants in India till date are mostly ground-mounted power plants. Due to initiative of Ministry of New and Renewable Energy, Government of India, many projects are coming up with rooftop solar PV installation. Most of the utility scale PV power plants are typically in the scale of 5 MW in size and connected to the electrical grid. The objective of this study is to present the economical evaluation of residential and commercial 100 KW roof top solar PV power ranging from 5 to 15kW and 25 to 100kW respectively. Economical feasibility of renewable energy is presented using Net Present Value (NPV), Return on Investment (ROI) and Internal Rate of Return (IRR) in many cases. In this report, financial analysis has been performed with Levelized Cost of Energy (LCOE), Pay Back Period (PBP) and Emission Reduction Benefit (EBP). Standard financial procedures have been used and the sensitivity parameters studied, mainly focusing on discount rate, inflation rate and sell back rate. The feasibility analysis results were discussed and presented in the conclusions. Keywords: Solar rooftop PV, Economic Evaluation, LCOE, PBP, EBP, Microgrid.

Chapter 1

Introduction

1.1 Overview of Power Sector

Growth of Power sector is key to the economic development of the country as it facilitates development across various sectors of the economy, such as manufacturing, agriculture, commercial enterprises and railways. Since independence the power sector in India has grown considerably. However, the enactment of Electricity Act, 2003, has brought in revolutionary changes in almost all the areas of the sector. Through this Act a conducive environment has been created to promote private sector participation and competition in the sector by providing a level playing field. This has led to significant investment in generation, transmission and distribution areas. Over the years the installed capacity of Power Plants (Utilities) has increased to 3,26,833 MW as on 31.3.2017 from a meagre 1,713 MW in 1950. Similarly, the electricity generation increased from about 5.1 Billion units in 1950 to 1,242 BU (including imports) in the year 2016- 17. The per capita consumption of electricity in the country has also increased from 15 kWh in 1950 to about 1,122 kWh in the year 2016-17. Regional grids have been integrated into a single national grid with effect from 31.12.2013 thereby providing free flow or power from one corner of the country to another through strong inter regional AC and HVDC links. As a result, the all India peak demand (MW) not met as well as energy (MU) not supplied

have registered steady decline. The peak not met and energy not supplied were 1.6% and 0.7% respectively during the year 2016-17. [1]

1.2 Background

1.2.1 Perspective of National Electricity Policy

National Electricity Policy stipulates that the National Electricity Plan would be for a short-term framework of five years while giving a 15-year perspective and would include [1]:

- Short-term and long term demand forecast for different regions
- Suggested areas/locations for capacity additions in generation and transmission keeping in view of the economics of generation and transmission, losses in the system, load centre requirements, grid stability, security of supply, quality of power including voltage profile, etc.; and environmental considerations including rehabilitation and resettlement
- Integration of such possible locations with transmission system and development of national grid including type of transmission systems and requirement of redundancies;
- Different technologies available for efficient generation, transmission and distribution.
- Fuel choices based on economy, energy security and environmental considerations.

This policy suggest that cost of electricity and environment consideration should brought together, which leads to use of renewable sources.

1.2.2 Tariff Policy 2016

The Central Government has notified the revised Tariff Policy vide Gazette notification dated 28.01.2016 in exercises of powers conferred under section 3(3) of Electricity Act, 2003. The Tariff Policy has been evolved in consultation with the State Governments, the Central Electricity Authority (CEA), the Central Electricity Regulatory Commission and various stakeholders. The objectives of this Tariff Policy are to [1]:

- 1. Ensure availability of electricity to consumers at reasonable and competitive rates;
- 2. Ensure financial viability of the sector and attract investments;
- 3. Promote transparency, consistency and predictability in regulatory approaches across jurisdictions and minimize perceptions of regulatory risks;
- 4. Promote competition, efficiency in operations and improvement in quality of supply;
- 5. Promote generation of electricity from renewable sources;
- 6. Promote hydroelectric power generation including Pumped Storage Projects (PSP) to provide adequate peaking reserves, reliable grid operation and integration of variable renewable energy sources;
- 7. Evolve a dynamic and robust electricity infrastructure for better consumer services;
- 8. Facilitate supply of adequate and uninterrupted power to all categories of consumers;
- 9. Ensure creation of adequate capacity including reserves in generation, transmission and distribution in advance, for reliability of supply of electricity to consumers.

The Tariff Policy 2016 is also giving importance to power generation through renewable energies.

1.2.3 Grid Connected Rooftop Solar Program

As a part of Intended Nationally Determined Contributions (INDCs), India has committed to increase the share of installed capacity of electric power from non-fossil-fuel sources to 40% by 2030. Solar energy is one of the main source to accomplish the target of 40% of electric power from non-fossil-fuel. Government of India has set the target of achieving 100 GW of solar power capacity in the country by the year 2022 of which 40 GW to be achieved from rooftop solar (RTS) [2].

The rooftop solar (RTS) plant is a system installed mainly on the roof of a building and includes installations on open contiguous land within the area of premises wherein valid and live electricity connection has been provided by the concern Distribution utilities/companies (DISCOMS). Typically, 1(one) kWp RTS plant requires about 10 sq. m area. The Solar power so generated can then be used either for captive consumption of the premises or can be fed into the grid and be adjusted in the electricity bill. Netmetering regulations notified by respective State Electricity Regulatory Commissions (SERCs) provide a legal framework for such adjustment. RTS plants help DISCOMs in reducing transmission and distribution losses as power consumption and generation are co-located. These Plants are also useful in tackling day time peak load as solar generation profile matches such peak loads during the day.

The Government, on 30th December 2015, approved a program "Grid Connected Rooftop and Small Solar Power Plants Programme" for installation of 4,200 MW RTS plants in the country by year 2019-20, of which 2,100 MW was through CFA and balance 2,100 MW was without CFA. The RTS projects sanctioned under this Program are under implementation by State Nodal Agencies (SNAs), Solar Energy Corporation of India (SECI), Public Sector Undertakings (PSUs) and other Government Agencies (GAs) [2].

The Government, on 19th February 2019 approved Phase-II of Grid Connected Rooftop and Small Solar Power Plants Programme for achieving cumulative capacity of 40 GW RTS plants by 2022. In Phase-II, it has been decided to implement the programme by making the DISCOMs and its local offices as the nodal points for implementation of the KΓS programme. DISCOMs will play a key role in expansion of RTS as DISCOMs are having direct contact with end user and they provide approval

for installation, manage the distribution network and also have billing interface with rooftop owner [2].

Aims and Objectives [2]: The key objectives of the programme are:

- 1. To promote grid connected RTS in all consumer segments, viz., residential, institutional, social, Govt., commercial, industrial etc.
- 2. To bring DISCOMs at forefront as key drivers for rapid deployment of RTS.
- 3. To create awareness, capacity building, human resource development, etc.
- 4. To promote sustainable business models.
- 5. To create additional RTS capacity of 38000 MW in the country by 31.12.2022 out of which a capacity of 4000 MW in residential sector with Central Financial Assistance and 34000 MW in other sectors (i.e., Social, Government, educational, PSUs, Statutory / Autonomous bodies, Private Commercial, Industrial Sectors etc.) by suitably incentivizing DISCOMs
- 6. To promote domestic manufacturing of solar cells and module

According to this program promoted by MNRE India, roof top solar PV installation at residential and commercial complex will start increasing.

1.3 Need for Research

To evaluate the economic and environmental performance of the solar PV Microgrids, investigation of typical PV Microgrid installed on the roof of a building is analyzing its operation mode and benefit to consumer, utility and society with the real operation data. The NPV and IRR systems of economic evaluation do not reflect about emission reduction. Hence new economic index must be introduced for economic evaluation of PV Microgrid. Levelized energy cost (LEC), emission reduction benefits (ERB) and payback period (PBP) are selected for economic evaluation as economic indices. This

gives economic scheduling and optimized model of PV Microgrid with impact of emission reduction.

1.4 Research Hypothesis

In last few decade, Photovoltaic(PV) systems have experienced remarkable growth, due to the rapid growth of the global PV industry, the continued expansion of the industrial scale, and the significant decrease of the PV module price. It brings us not only direct economic benefits but also indirect benefits such as energy saving, emission reduction, loss reduction, reliability improvement, and deferral of grid construction, etc. The economic evaluation on Microgrid should not be limited to its finance only. Net contributions of PV Microgrid to the national economy and whole society must be evaluated. In the aspect of optimal allocation of PV Microgrids, some analytical methodologies have been presented for the optimal implementation. This study proposes, new method for economic evaluation of PV Microgrid with case study.

In Microgrid there are different distributed energy recourses such as wind, solar, biomass, micro-turbine. Due to large availability and attractive government policies, solar PV Microgrid is proven to be best for investment. Hence its economical analysis must be carried out with new indices. To quantitatively evaluate the economic and environmental performances of the PV Microgrids based on local energy prices, photovoltaic array generating capacity and other data in the project, three indexes are introduced here: Levelized Energy Cost (LEC), Emission Reduction Benefit (ERB) and Payback Period (BPP).

Chapter 2

Literature Review

2.1 Introduction

Following are the major areas to reach upto research hypothesis which may be categories as broad and narrow area of research:

- 1. Microgrid Power System (Broad area)
- 2. Renewable energy in Microgrid and challenges (Broad area)
- 3. Solar rooftop design and implementation (Narrow area)
- 4. Economic evaluation using different indices (Narrow area)

2.1.1 Microgrid Power System (Broad area)

Many believe the electric power system is undergoing a profound change driven by a number of needs. There's the need for environmental compliance and energy conservation. This transformation will be necessary to meet environmental targets, to accommodate a greater emphasis on demand response (DR), and to support plug-in hybrid electric vehicles (PHEVs) as well as distributed generation and storage capabilities [3]. According to US department of energy, distributed generation is the use of small-scale

power generation technologies located close to the load being served, capable of lowering costs, improving reliability, reducing emissions and expanding energy options [4]. New trends of the development of microgrids are including higher renewable energy integration, multi-level architecture, demand side management, generalized storage. These trends make microgrid be more economic, efficient and green, but also bring new challenges [5].

2.1.2 Renewable energy in Microgrid and challenges (Broad area)

The impact of microgrid and distributed energy challenges are discussed in [6] and its impact study is give in [7]. Major challenges in implementation of distributed generation in microgrid are stability, protection, architecture design, operation strategies, converter designed and most importantly complex economics. Although the construction costs of microgrid are higher, it is economic to invest in microgrid in view of its social benefits in improving reliability, energy saving and emission reduction, environmental protection and deferral of investment in transmission and distribution grids [8–10].

2.1.3 Solar rooftop design and implementation (Narrow area)

Total solar PV generation is 16% of total RES installed capacity as on 30.03.2016 and it is expected to grow further with tremendous rate due to different policies to promote solar PV generation [11]. Comprehensive benefits analysis and economic evaluation of Microgrid [12] shows the importance of economic evaluation and its process.

Economic evaluation of PV Microgrid must be carried out before implementation the project. There are some researches on the economic evaluation of PV Microgrid to understand different affecting parameters to the investment in [12–17]. Besides, the economic return of grid-connected photovoltaic system is investigated in a global view in [18]. The performance and economic evaluation of photovoltaic power generation projects in different countries are discussed in [19–21]. Reduction of voltage drop and

power system loss can be obtained with the PV system installed to provide the dispersed generation for the local loads. However, the PV system penetration is limited due to the violation of voltage variation introduced by the large intermittent PV power generation is discussed in [22].

2.1.4 Economic evaluation using different indices(Narrow area)

However, most papers are mainly concentrated in the net present value (NPV) [21,23] and the internal rate of return (IRR) [24]. It shows that there is less research carried out which focus on the economic evaluation of the emission reduction benefits of PV Microgrids, especially for the non counter current systems. Economic performances of microgrids with SS-PVs specifically for industries by comprehensively considering three indexes of LEC, ERB, and PBP and using real operation data of the microgrid and optimal simulation results are discussed in [25]. Economic feasibility of a residential solar microgrid connected to the distribution system without any energy storage system is carried out in [26]. These all papers are giving importance to levelized cost of energy (LCOE), pay back period (PBP) and emission reduction benefits (ERB) than net present value (NPV) [21,23] and the internal rate of return (IRR) in economic evaluation of grid connected solar PV based microgrid system.

2.2 Factor Critical to Success of Study

In order to be able to realistically model the variations in market prices and fluctuations in full load hours (FLH) within respective technologies, upper and lower price limits are indicated. These limits are chosen based on a technology cost analysis of individual components, market and literature research as well as latest reports from current power plants. It should be noted that market prices are often based on applicable feedin tariffs and are therefore not always in free competition. Characteristics of individual technologies that cannot be mapped into LCOE, such as the advantages of easily integral storage, the number of FLH, decentralized power generation, capacity for follow-up op-

eration and time of day availability, have not been taken into account. The technologies are evaluated and compared based on standard market financing costs and historically proven learning curves.

To evaluate economics of solar PV based microgrid connected to microgrid on the basis of new indices levelized cost of energy (LCOE), pay back period (PBP) and emission reduction benefits (ERB), following parameters must be known before:

- 1. Type of renewable energy available
- 2. Specific investment cost for the construction and installation of power plants with upper and lower limits; determined based on current power plant and market data
- 3. Local condition with typical irradiation and wind conditions for different locations and full load hours (FLH) in the energy system
- 4. Operating and maintenance cost during the power plant?s operational life time
- 5. Lifetime of the plant for which plant is working in good condition
- Financing condition earnings calculated on the financial market and maturity
 periods based on technology-specific risk surcharges and country specific financing
 conditions taking into account the respective shares of external and equity-based
 financing.

2.3 Summary

Decarbonisation and transformation of the energy system are associated with both technical and economic efforts. The cost of current and future power generation is heavily dependent on the cost of expanding and operating power plants. The costs of renewable energy technologies in particular have changed dramatically in recent years. This development is driven by technological innovations such as the use of less-expensive and

better- performing materials, reduced material consumption, more efficient production processes, increasing efficiency as well as automated mass production of components. For these reasons, the aim of this study is to analyze the current and future cost situation as transparently as possible in the form of LCOE, PBP and ERB.

Chapter 3

Research Design, Methodology and

Plan

3.1 Introduction

Decaronisation and transformation of the energy system are associated with both technical and economic efforts. The cost of current and future power generation is heavily dependent on the cost of expanding and operating power plants. The costs of renewable energy technologies in particular have changed dramatically in recent years. This development is driven by technological innovations such as the use of less-expensive and better- performing materials, reduced material consumption, more efficient production processes, increasing efficiency as well as automated mass production of components. For these reasons, the aim of this study is to analyze the current and future cost situation as transparently as possible in the form of LCOE.

3.2 Research Plan

Research plan for this study is given below:

- Analysis of the current situation and the future market development of photovoltaic
 (PV) in India
- 2. Economic modeling of technology-specific LCOE for PV installations at residential and Commercial site on the basis of common market financing costs
- 3. Assessment of the different technology and financial parameters based on sensitivity analyzes of the individual technologies
- 4. Forecast the future LCOE of renewable energy technologies using learning curve models and market growth scenarios
- 5. Analysis of the current situation and future market development of photovoltaic solar power plants for locations with favorable solar irradiance.
- 6. Analysis of electricity generation costs of PV storage systems

3.3 Historical Development of Renewable Energy Technology

3.3.1 Global Review

The visualisation shows the global production of renewable energy over the long-term. As we see, historical production of renewable energy has been dominated by traditional biomass—the burning of wood, forestry materials and agricultural waste biomass. Although implemented at smaller scales for thousands of years, across a range of countries, hydropower output did not feature at large production scales with pumped storage development until the 1920s.

Today, traditional biofuels remain the largest source of renewables, accounting for 60-70 percent of the total. Traditional biomass remains the dominant fuel source for cooking & heating across many low-income households. The World Bank reports that only 7 percent of the worlds low-income households have access to clean fuels and technologies

for cooking; the average share in Sub-Saharan Africa was 13 percent; and approximately one-third in South Asia. Among the remaining renewable technologies, hydropower remains dominant, accounting for approximately one-quarter of renewable consumption.

Renewable technologies with exception to traditional biomass are often termed 'modern renewables'. These include hydropower, solar, wind, geothermal and modern biofuel production (including modern forms of waste-to-biomass conversion). The change and mix of modern renewable consumption over the last 50 years is shown in the Fig.3.1. This is measured in terawatt-hours per year and can be viewed across a range of countries and regions.

Globally, the world produced approximately 5.9 TWh of modern renewable energy in 2016. This represents a 5 to 6-fold increase since the 1960s. Here we see that hydropower remains the dominant form of modern renewables consumption, accounting for almost 70 percent. Despite absolute growth in production, hydropowers share is, however, declining as other renewable technologies grow.




Figure 3.1: Global renewable energy consumption

Globally, the world produced approximately 585 TWh through solar PV generation in 2018 which was negligible in 2000 (see Fig.3.2). This shows significant change in solar PV applications in last decade. In Asia pacific region, the growth in renewable energy

is recorded 300 to 350% in last 20 years. It shows large potential of solar PV projects in India also [27].




Figure 3.2: Solar energy generation by region

3.3.2 National Review

India is one of the countries with the largest production of energy from renewable sources. As of 2019, 35% of India's installed electricity generation capacity is from renewable sources, generating 17% of total electricity in the country.

Coal power currently represents the largest share of installed capacity at just under 194 GW. Total installed capacity as of 30 June 2019 (see Fig.3.3), for grid connected power in India stood at a little under 358 GW [28].

The fast growing renewable energy sources under the responsibility of the Ministry for New and Renewable Energy exceeded the installed capacity of large hydro installations (see Fig.3.4) [29]. This figure is targeted to reach 175 GW by 2022.

The 2022 electrical power targets include achieving 227GW (earlier 175 GW) of energy from renewable sources - nearly 113 GW through solar power, 66 GW from wind




Figure 3.3: Installed grid power capacity from all sources in India as of 30 June 2019

power, 10 GW from biomass power, 5GW from small hydro and 31GW from floating solar and offshore wind power. The bidding process for the further additional 115 GW or thereabouts to meet these targets of installed capacity from January 2018 levels will be completed by the end of 2019-2020. The government has announced that no new coal-based capacity addition is required beyond the 50 GW under different stages of construction likely to come online between 2017 and 2022. With the expansion of renewable power generation capacity, the outstanding payment dues from the power purchasers are also increasing due to their weak purchasing capacity.




Figure 3.4: Installed grid interactive renewable power capacity in India as of 30 June 2019 (excluding large hydro)

3.4 Input Data for Calculation of Levelized Cost of Energy(LCOE)

3.4.1 Size and cost of solar PV system

For PV, the upper and lower limits for the installation cost are differentiated according to the system sizes of small rooftop systems up to 15 kWp, large rooftop systemy up to 1000 kWp and ground-mounted PV systems. By using these costs, the LCOE for each point of time for investment and construction are calculated. The financial lifetime of PV is set to 25 years. Longer lifetimes and operation of PV are also reported by the plant monitoring in different countries.

To calculate cost of rooftop solar PV, Solar Rooftop Calculator from MNRE site is used. The deatils are given in Table 3.1

Table 3.1: Size and cost of solar PV system

| Parameter | | Solar Roc | ftop | Source |
|---|---------------|---------------------|-------------|-----------------|
| | <u>1-10kW</u> | $11-100\mathrm{kW}$ | 101kW-500kW | |
| Cost (Rs kW) | 60000 | 55000 | 53000 | MNRE calculator |
| Lifetime (yrs) | 25 | 25 | 25 | Own Assumption |
| Share of Debt (%) | 70 | 70 | 70 | MNRE calculator |
| Share of Equity (%) | 30 | 30 | 30 | MNRE calculator |
| Average solar irradi- | 1266.52 | 1266.52 | 1266.52 | MNRE calculator |
| | | | | |
| ation (W sq.m) | | | | |
| Average generation | 5 | 5 | 5 | MNRE calculator |
| | | | | |
| (units kWp day) | | | | • |
| O & M cost (Rs year | 6600 | 5500 | 5300 | Own assumption |
| | | | | • |
| kW) | | | * * | |
| Replacement cost | 60000 | 55000 | 53000 | Own Assumption |
| Top | 50000 | 33333 | 00000 | Own Postumpuon |
| (7)) (6) (10) | | | • | |
| (Rs) (after 20 yrs) | | | / | |

3.4.2 Cost of energy from grid

In Maharashtra, electricity is distributed though Maharashtra State Electricity Distribution Company Ltd. (MAHADISCOM). After analyzing the electricity bills for residential and commercial consumers, the rate of electrical energy from grid is given in Table 3.2

Table 3.2: Cost of energy from grid

| Type of Consumer | Grid Power Price (Rs/kWh) | Grid Power Price (Rs/kWh) |
|------------------|------------------------------|------------------------------|
| Residential | 8 | 2.8-3.2 |
| Commercial | 14 | 2.8-3.2 |

3.4.3 Load Profile

To determine economic evaluation, it is necessary to input the data for average energy consumed per day. Table 3.3 gives average energy consumed per day by residential and commercial consumer.

Table 3.3: Load Profile

| Type of consumer | Energy consumed (units/day) | Peak Demand (kw) | Peak month |
|------------------|-----------------------------|---------------------|------------|
| Residential | 10 | 2.06 | January |
| Commercial | 80 | 13.47 | January |

Daily and yearly average load curve for residential consumer is given in Fig.3.5 and Fig.3.6

Daily and yearly average load curve for commercial consumer is given in Fig.3.7 and Fig.3.8 $\,$




Figure 3.5: Daily load curve (Residential)




Figure 3.6: Yearly load curve (Residential)




Figure 3.7: Daily load curve (commercial)




Figure 3.8: Yearly load curve (commercial)

3.5 Levelized Cost of Energy (LCOE)

To calculate LCOE, following assumptions are made

- 1. Nominal discount rate is considered 4%, 6%, 8%.
- 2. Expected inflation is considered 0%, 2%, 4%.
- 3. Selback rate of energy is considered Rs.2.8/unit,Rs.3.0/unit,Rs.3.2/unit.

The LCOE is calculated using HOMER software.

3.5.1 Calculation of LCOE

HOMER defines the levelized cost of energy (COE) as the average cost per kWh of useful electrical energy produced by the system.

Type: Output Variable

Units: \$ kWh

Symbol:COE

To calculate the COE, HOMER divides the annualized cost of producing electricity (the total annualized cost minus the cost of serving the thermal load) by the total electric load served, using the following equation:

$$COE = \frac{C_{ann,tot} - C_{boiler} H_{served}}{E_{served}}$$
(3.1)

where $C_{ann,tot}$ = total annualized cost of the system [Rs/yr]

 C_{boiler} = boiler marginal cost [Rs/kWh]

 $H_{served} = \text{total thermal load served [kWh/yr]}$

 E_{served} = total electrical load served [kWh/yr]

The second term in the numerator is the portion of the annualized cost that results from serving the thermal load. In systems, such as wind or PV, that do not serve a thermal load (Hthermal=0), this term is zero.

The COE is a convenient metric with which to compare systems, but HOMER does not rank systems based on COE.

3.5.2 Annualized Cost

The annualized cost of a component is the cost that, if it were to occur equally in every year of the project lifetime, would give the same net present cost as the actual cash flow sequence associated with that component.

HOMER calculates annualized cost by first calculating the net present cost, then multiplying it by the capital recovery factor, as in the following equation:

$$C_{ann} = CRF(i, R_{prc_i})C_{NPC}) (3.2)$$

where: C_{NPC} = the net present cost [Rs]

i =the annual real discount rate [%]

 R_{proj} = the project lifetime [yr]

CRF() = a function returning the capital recovery factor

The annualized cost serves as a useful metric for comparing the costs of different components because it measures their relative contribution to the total net present cost. It allows for a fair cost comparison between components with low capital and high operating costs (such as diesel generators) and those with high capital and low operating costs (such as PV arrays or wind turbines).

The annualized costs of each system component and of the system as a whole appear on the Cost Summary tab of the Simulation Results window.

3.5.3 Net Present Cost (NPC)

The net present cost (or life-cycle cost) of a Component is the present value of all the costs of installing and operating the Component over the project lifetime, minus the present value of all the revenues that it earns over the project lifetime. HOMER calculates the net present cost of each Component in the system, and of the system as a whole.

3.5.4 Annual Real Discount Rate

The real discount rate is used to convert between one-time costs and annualized costs. HOMER calculates the annual real discount rate (also called the real interest rate or interest rate) from the "Nominal discount rate" and "Expected inflation rate" inputs. HOMER uses the real discount rate to calculate discount factors and annualized costs from net present costs. HOMER uses the following equation to calculate the real discount rate:

$$i = \frac{i' - f}{1 + f} \tag{3.3}$$

where i = real discount rate

i' = nominal discount rate (the rate at which you could borrow money)

f =expected inflation rate

3.5.5 Capital Recovery Factor

The capital recovery factor is a ratio used to calculate the present value of an annuity (a series of equal annual cash flows). The equation for the capital recovery factor is:

$$CRF(i,N) = \frac{i(1+i)^N}{(1+i)^N - 1}$$
(3.4)

where:i = real discount rate

N = number of years.

3.6 Site Selection

For installation of solar rooftop PV system, two sites has been considered. For residential, we choose my own apartment, whose terrace area is approximately 3200 sq.ft. Approximately 50% area of the terrace (3200/2=1600 sq.ft) can be utilized to install solar rooftop upto 13.8kW as per calculation from solar rooftop calculator by MNRE, India.

Similarly For commercial, we choose my own institute, where approximately we can utilize 1000 sq.m. area to install solar rooftop upto 100kW as per calculation from solar rooftop calculator by MNRE, India.

3.7 Procedure Followed for Economic Evaluation of solar rooftop PV

Following steps are carried out for economic evaluation of solar rooftop PV.

- Selection of site for solar rooftop PV installation.
- Load survey of particular premises.
- Calculation of solar PV generation potential.
- Survey of current supply system.
- Feeding all data to HOMER software
- Analysis of data with sensitivity parameters such as sellback cost, inflation rate, discount rate.
- Select optimized design on the basis of LCOE, PBP and ERB.

Chapter 4

System Description, Result and

Analysis

4.1 System Description: Case-I Residential Project

Input Summary

Project title

Gokuldham Residency Apartment, Audumbar Nagar Nashik

Author

Ganesh N Jadhav

Notes

Project Location

Location

217, Sagar Township, Ayodhya nagari, Nashik, Maharashtra 422003, India

Latitude

20 degrees 1.25 minutes North

Longitude

73 degrees 49.58 minutes East

Time zone

Asia/Kolkata

Load: Electric1

Data source

Synthetic

Daily noise

10%

Hourly noise

20%

Scaled annual average


10.000 kWh/d

Scaled peak load

2.0585 k\V

Load factor

0.2024



Microgrid Controller: HOMER Cycle Charging

| Quantity | Capital | Replacement | O&M |
|----------|---------|-------------|-------|
| 1 | ₹0.00 | ₹0.00 | ₹0.00 |
| | | | |


| Minimization strategy | Economic |
|---|----------|
| Setpoint state of charge | 80 |
| Allow multiple generators to operate simultaneously | Yes |
| Allow systems with generator capacity less than peak load | Yes |
| Allow diesel off operation | Yes |

PV:Generic flat plate PV

| Size Capital | Replacement | O&M |
|--------------------|-------------|--|
| Sizes to consider | 0,5,7.5,10 | 0 |
| Lifetime | 20 yr | nana makamana kanana kanana arawa araw Arawa arawa |
| Derating factor | 80% | |
| Tracking system | No Track | ing |
| Slope | 20.021 de | eg |
| Azimuth | 0.000 deg | g |
| Ground reflectance | 20.0% | mpch wathaw Mile Production of the Management and approximately lead to the angle of the leads o |

Solar Resource


| The same and the s | ence to a contraction to make the contraction of th | and the second of the second o |
|--|--|--|
| Scaled annual average | 5.19 kWh/m2/d | |
| Scared arrida. average | 3.17 KVVN/IIIZ/U | |
| | | |



Wind Resource

| Scaled annual average 3.3 | C |
|---------------------------|---|
| Sealed diffical dverage | 7 |
| | |





Fuel: Diesel

| Price | ₹ 70.00/L |
|---------------------|--------------|
| Lower heating value | 43.2 MJ/kg |
| Density | 820.00 kg/m3 |
| Carbon content | 88.0% |
| Sulfur content | 0.4% |

Economics

| Annual real interest rate | 0% |
|---------------------------|-------|
| Project lifetime | 25 yr |

| Capacity shortage penalty | ₹0/k | Wh |
|--|------------------|------|
| System fixed capital cost | 0 | |
| System fixed O&M cost | 0 | |
| System control | | |
| Timestep length in minutes | | 60 |
| Multi-Year enabled | | No |
| Ailow systems with multiple generators | | Yes |
| Allow systems with multiple wind turbine types | | No . |
| Battery autonomy threshold | | 2 |
| Maximum renewable penetration threshold | | 50 |
| Warn about renewable penetration | | Yes |
| Optimizer | | |
| Maximum simulations | 10000 | |
| System design precision | 0.01 | |
| NPC precision | 0.01 | |
| Minimum spacing | 0 | |
| Focus factor | 100.002981445635 | |

Yes

No

Optimize category winners

Use base case

Emissions

| Carbon dioxide penalty | ₹ 0/t |
|---|-------|
| Carbon monoxide penalty | ₹ 0/t |
| Unburned hydrocarbons penalty | ₹0/t |
| Particulate matter penalty | ₹ 0/t |
| Sulfur dioxide penalty | ₹0/t |
| Nitrogen oxides penalty | ₹0/t |
| Constraints | |
| Maximum annual capacity shortage | 5 |
| Minimum renewable fraction | 0 |
| Operating reserve as percentage of hourly load | 10 |
| Operating reserve as percentage of peak load | 0 |
| Operating reserve as percentage of solar power output | 80 |
| Operating reserve as percentage of wind power output | 50 |

4.2 System Description: Case-II Commercial Project

Input Summary

Project title

K.K. Wagh Institute of Engineering Education and Research, Nashik

Author

Ganesh N. Jadhav

Notes

Project Location

Location K.K. Wagh Building, Mumbai Agra Rd, Durga Nagar, Nashik, Maharashtra 422006, India

Latitude 20 degrees 0.82 minutes North

Longitude 73 degrees 49.38 minutes East

Time zone Asia/Kolkata

Load: Electric1

Data source Synthetic


Daily noise 10%

Hourly noise 20%

Scaled annual average 80.000 kWh/d

Scaled peak load 13.4664 kW

Load factor 0.2475



Microgrid Controller: HOMER Cycle Charging

| Quantity | Capital | Replacement | O&M |
|----------|---------|-------------|-------|
| 1 | ₹0.00 | ₹0.00 | ₹0.00 |


| Minimization strategy | Economic |
|---|----------|
| Setpoint state of charge | 80 |
| Allow multiple generators to operate simultaneously | Yes |
| Allow systems with generator capacity less than peak load | Yes |
| Allow diesel off operation | Yes |

PV:Generic flat plate PV

| Size | Capital | Replacement | O&M |
|------------------|--|--|--|
| Sizes to conside | er | 0,25,50,75,100 | |
| Lifetime | the control of the co | 20 yr | en e |
| Derating factor | | 80% . | |
| Tracking system |) | Horizontal Axis, monthly adjustmer | nt |
| Slope | ere page, commente per experience de la commente d | 20.014 deg | The first of the second second control of the second secon |
| Azimuth | *************************************** | 0.000 deg | |
| Ground reflecta | ance | 20.0% | Committee with the anti-committee of the committee of the |
| | | Because of the second of the s | |


Solar Resource

| • | | |
|--|--|--------------------------------------|
| The state of the s | Consider a company of the company of the company of the constant of the consta | and the same of the same of the same |
| | | |
| Cooled applied average | 5.401348.7.071 | |
| Scaled annual average | 5.19 kWh/m2/d | |
| - - | | 1 |
| | | |
| 1 | | |



Wind Resource

| Scaled annual average | | 3.39 | |
|-----------------------|--|------|--|
| | | 0.07 | |
| | | | |



Fuel: Diesel

| Price | ₹ 70.00/L |
|---------------------|--------------|
| Lower heating value | 43.2 MJ/kg |
| Density | 820.00 kg/m3 |
| Carbon content | 88.0% |
| Sulfur content | 0.4% |

Economics

| Annual real interest rate | 4% |
|---------------------------|-------|
| Project lifetime | 25 yr |

| Capacity shortage penalty | ₹0/kWh |
|---------------------------|--------|
| System fixed capital cost | 0 |
| System fixed O&M cost | 0 |

System control

| Timestep length in minutes | 60 |
|--|-----|
| Multi-Year enabled | No |
| Allow systems with multiple generators | Yes |
| Allow systems with multiple wind turbine types | Yes |
| Battery autonomy threshold | 2 |
| Maximum renewable penetration threshold | 55 |
| Warn about renewable penetration | Yes |

Optimizer

| | • | |
|---------------------------|--|-------|
| Maximum simulations | ty the water was a second of the second of t | 10000 |
| System design precision | | 0.01 |
| NPC precision | | 0.01 |
| Minimum spacing | | 0 |
| Focus factor | | 50 |
| Optimize category winners | | Yes |
| Use base case | | No |

Emissions

| Carbon dioxide penalty | ₹ 0/t | |
|---|----------------|----|
| Carbon monoxide penalty | ₹ 0/t | |
| Unburned hydrocarbons penalty | ₹0/t | |
| Particulate matter penalty | ₹ 0/t | |
| Sulfur dioxide penalty | ₹ 0/t | |
| Nitrogen oxides penalty | ₹ 0/t | |
| Constraints | | |
| Maximum annua! capacity shortage | | 5 |
| Minimum renewable fraction | · | 0 |
| Operating reserve as percentage of hourly load | | 10 |
| Operating reserve as percentage of peak load | | 0 |
| Operating reserve as percentage of solar power output | A A CONTRACTOR | 80 |
| | | |

50

Operating reserve as percentage of wind power cutput

4.3 Result:Case-I Residential Project

After inputting data to HOMER software, simulation is carried out for different situations given in Table 4.1


Table 4.1: Different cases for which simulations are carried out Y: Feasible N: Not Feasible

| Configuration: 5kW | Configuration: 5kW PV+ Grid | | | |
|------------------------------------|-----------------------------|--|--|--|
| Sellback Rate Rs.2.8/kWh R | Rs.3/kWh Rs.3.2/kWh | | | |
| Discount Rate | i | | | |
| Inflation Rate 0% 2% 4% 0% | 12% 4% 0% 2% 4% | | | |
| 0% Y Y Y Y | Y Y Y Y Y | | | |
| 4% Y Y Y Y | Y Y Y Y Y | | | |
| 6% Y Y Y Y | Y Y Y Y Y | | | |
| 8% Y Y Y Y | Y Y Y Y Y | | | |
| Configuration: 7.5kW | V PV+ Grid | | | |
| Sellback Rate Rs.2.8/kWh R | Rs.3/kWh Rs.3.2/kWh | | | |
| Discount Rate | | | | |
| Inflation Rate 0% 2% 4% 0% | 12% 4% 0% 2% 4% | | | |
| 0% Y Y Y Y | Y Y Y Y Y | | | |
| 4% Y Y Y Y | Y Y Y Y Y | | | |
| 6% Y Y Y | Y Y Y Y Y | | | |
| 8% Y Y Y | Y Y Y Y Y | | | |
| Configuration: 10kW | / PV+ Grid | | | |
| Sellback Rate Rs.2.8/kWh R | ks.3/kWh Rs.3.2/kWh | | | |
| Inflation Rate | | | | |
| Discount Rate 0% 2% 4% 0% | 12% 4% 0% 2% 4% | | | |
| 0% Y Y Y Y | Y N Y Y N | | | |
| 4% Y Y Y Y | Y Y Y Y Y | | | |
| 6% Y Y Y Y | Y Y Y Y Y | | | |
| 8% Y Y Y | Y Y Y Y Y | | | |

The simulation result report generated by HOMER for 10kW PV+Grid, Discount Rate=8%, Inflation Rate=4%, Sellback rate=Rs.3.2 kWh is given below.



System Simulation Report



File: Residential.homer

Author: Ganesh N Jadhav

Location: 217, Sagar Township, Ayodhya nagari, Nashik, Maharashtra 422003, India

(20°1.2'N, 73°49.6'E)

Total Net Present Cost: ₹362,159.30

Levelized Cost of Energy (₹/kWh): ₹1.27

Notes:

Sensitivity variable values for this simulation

| Variable | Value - | Unit | 第一个人的 |
|-----------------------|---------|-------|--------------|
| Seilback Rate | 3.20 | ₹/kWh | |
| ExpectedInflationRate | 4.00 | % | |
| NominalDiscountRate | 8.00 | % | |



Table of Contents


| System Architecture | 3 |
|---------------------------|----|
| Cost Summary | 4 |
| Cash Flow | 5 |
| Electrical Summary | 6 |
| PV: Generic flat plate PV | 7 |
| Grid: Grid | 8 |
| Renewable Summary | 10 |
| Compare Economics | 11 |



System Architecture


| Component | Name | Size | Unit |
|-------------------|-----------------------|------|------|
| PV | Generic flat plate PV | 10.0 | kW |
| Grid | Grid | 10.0 | kW |
| Dispatch strategy | HOMER Cycle Charging | | |

Schematic





Cost Summary



Net Present Costs


| Name - | _Capital | Operating | Replacement | Salvage | -Resource - | _ Total |
|--------------|----------|-----------|-------------|---|-------------|-----------|
| Generic flat | | | | STANDARD AND AND AND AND AND AND AND AND AND AN | | |
| plate PV | ₹600,000 | ₹158,792 | ₹282.061 | -₹175,167 | ₹0.00 | ₹865,686 |
| Grid | ₹0.00 | -₹503,527 | ₹0.00 | ₹0.00 | ₹0.00 | -₹503,527 |
| System | ₹600,000 | -₹344,735 | ₹282,061 | -₹175,167 | ₹0.00 | ₹362,159 |

Annualized Costs

| Ñame | Capital | - Operating | Replacement | Salvage | Resource | - Total - |
|--------------|---------|-------------|-------------|----------|---|-----------|
| Generic flat | | | | | 8.45 A 3.54 A 3.5 A | |
| plate PV | ₹37,785 | ₹10,C00 | ₹17,763 | -₹11.031 | ₹0.00 | ₹54,517 |
| Grid | ₹0.00 | -₹31,710 | ₹0.00 | ₹0,00 | ₹0,00 | -₹31,710 |
| System | ₹37,785 | -₹21,710 | ₹17,763 | -₹11,031 | ₹0.00 | ₹22,807 |



Cash Flow





Electrical Summary

Excess and Unmet

| Quantity | Value | Units |
|---------------------|---|--------------|
| Excess Electricity | 0 | kWh/yr |
| Unmet Electric Load | 0 | kWh/yr |
| Capacity Shortage | Order to the control of the control | kWh/yr |

Production Summary

| Component _ | Production (kWh/yr) | Percent |
|-----------------------|---------------------|---------|
| Generic flat plate PV | 16,202 | 90.2 |
| Grid Purchases | 1,762 | 9.81 |
| Total | 17,964 | 100 |

Consumption Summary

| Component | Consumption (kWh/yr) | Percent |
|-----------------|----------------------|---------|
| AC Primary Load | 3,650 | 20.3 |
| DC Primary Load | 0 | 0 |
| Deferrable Load | 0 | |
| Grid Sales | 14,314 | 79.7 |
| Total | 17,964 | 100 |



PV: Generic flat plate PV


Generic flat plate PV Electrical Summary

| Quantity | Value | Units | THE REST OF STREET |
|--------------------|-------|--------|-----------------------|
| Minimum Output | 0 | kW | MSH SPACE |
| Maximum Output | 9.89 | kW | |
| PV Penetration | 444 | % | |
| Hours of Operation | 4,407 | hrs/yr | |
| Levelized Cost | 3.36 | ₹/kWh | Section in the second |

Generic flat plate PV Statistics

| Quantity | Value | Units | が対象を |
|------------------|--------|--------|------|
| Rated Capacity | 10.0 | kW | |
| Mean Output | 1.85 | kW | |
| Mean Output | 44.4 | kWh/d | |
| Capacity Factor | 18.5 | % | |
| Total Production | 16,202 | kWh/yr | |

Generic flat plate PV Output (kW)





Grid: Grid

Grid rate: Demand 1

| Month | Energy Purchased (kWh) | Energy Sold (kWh) | Net Energy Purchased (kWh) | Peak Demand (kW) | Energy Charge | Demand Charge |
|-----------|------------------------------|----------------------|----------------------------------|---------------------|---------------|------------------|
| January | 0 | 0 | 0.44 | 2.06 | ₹0.00 | ₹0.00 |
| February | 0 | 0 | 0 | 1.75 | ₹0.00 | ₹0.00 |
| March | 0 | 0 | 0 | 1.55 | ₹0.00 | ₹0.00 |
| April | 0 | 0 | 0 | 1.43 | ₹0.00 | ₹0.00 |
| May | 0 | 0 | 0 | 1.29 | ₹0.00 | ₹0.00 |
| June | 0 | 0 | 0 | 1.20 | ₹0.00 | ₹0.00 |
| July | 0 | 0 | 0 | 0.967 | ₹0.00 | ₹0.00 |
| August | 0 | 0 | 0 | 1.13 | ₹0.00 | ₹0.00 |
| September | 0 | O | 0 | 1.50 | ₹0.00 | ₹0.00 |
| October | 0 | 0 | 0 | 1.59 | ₹0.00 | ₹0.00 |
| November | 0 | 0- | 0 | 2.05 | ₹0.00 | ₹0.00 |
| December | 0 | 0 | 0 | 1.81 | ₹0.00 | ₹0.00 |
| Annual | 0 | 0 | 0 | 2.06 | ₹0.00 | ₹0.00 |

Grid rate: Rate 1

| – Month | Energy Purchased (kWh) | Energy Sold (kWh) | Net Energy Purchased— — (kWh) | Peak Demand (kW) | Energy Charge | Demand Charge |
|------------|------------------------------|----------------------|-------------------------------------|------------------|---------------|------------------|
| January | 191 | 1,358 | -1,167 | 0 | -₹2,820 | ₹0.00 |
| February | 157 | 1,329 | -1,172 | 0 | -₹2,996 | ₹0,00 |
| March | 163 | 1,514 | -1,351 | 0 | -₹3,541 | ₹0.00 |
| April | 143 | 1,429 | -1,286 | 0 | -₹3,427 | ₹0.00 |
| May | 122 | 1,370 | -1,248 | 0 | -₹3,405 | ₹0.00 |
| June | 110 | 965 | -856 | 0 | -₹2,210 | ₹0.00 |
| July | 109 | 761 | -652 | 0 | -₹1,562 | ₹0.00 |
| August | 121 | 746 | -625 | 0 | -₹1,419 | ₹0.00 |
| September | 134 | 972 | -838 | 0 | -₹2,040 | ₹0.00 |
| October | 154 | 1,308 | -1,154 | 0 | -₹2,955 | ₹0.00 |
| November | 170 | 1,289 | -1.119 | 0 | -₹2,765 | ₹0.00 |
| December | 187 | 1,270 | -1,083 | 0 | -₹2,568 | ₹0.00 |
| Annual | 1,762 | 14,314 | -12,552 | 0 | -₹31,710 | ₹0,00 |


Grid rate: All

| | | | | A Committee of the Comm | | |
|-----------|------------------------------|----------------------|--------------------------------|--|---------------|------------------|
| Month | Energy Purchased (kWh) | Energy Sold (kWh) | Net Energy - Purchased _ (kWh) | Peak Demand (kW) | Energy Charge | Demand Charge |
| January | 191 | 1,358 | -1,167 | 2.06 | -₹2,820 | ₹0.00 |
| February | 157 | 1,329 | -1,172 | 1.75 | -₹2,996 | ₹0.00 |
| March | 163 | 1,514 | -1,351 | 1.55 | -₹3,541 | ₹0.00 |
| April | 143 | 1,429 | -1,286 | 1.43 | -₹3,427 | ₹0.00 |
| Mav | 122 | 1,370 | -1,248 | 1.29 | -₹3,405 | ₹0.00 |
| June | 110 | 966 | -856 | 1.20 | -₹2,210 | ₹0.00 |
| July | 109 | 761 | -652 | 0.967 | -₹1,562 | ₹0.00 |
| August | 121 | 746 | -625 | 1.13 | -₹1,419 | ₹0.00 |
| September | 134 | 972 | -838 | 1.50 | -₹2,040 | ₹0.00 |
| October | 154 | 1,308 | -1,154 | 1.59 | -₹2,955 | ₹0.00 |
| November | 170 | 1,289 | -1,119 | 2.05 | -₹2,765 | ₹0.00 |
| December | 187 | 1,270 | -1,083 | 1.81 | -₹2,568 | ₹0.00 |
| Annual | 1,762 | 14,314 | -12,552 | 2.06 | -₹31,710 | ₹0.00 |






Energy Purchased From Grid (kW)



Energy Sold To Grid (kW)







Renewable Summary

| Capacity-based metrics | Value | Unit |
|--|-------|------|
| Nominal renewable capacity divided by total nominal capacity | 100 | % |
| Usable renewable capacity divided by total capacity | 100 | % |
| Energy-based metrics | Value | Unit |
| Total renewable production divided by load | 90.2 | % |
| Total renewable production divided by generation | 90.2 | % |
| One minus total nonrenewable production divided by load | 100 | % |
| Peak values | Value | Unit |
| Renewable output divided by load (HOMER standard) | 100 | % |
| Renewable output divided by total generation | 100 | % |
| One minus nonrenewable output divided by total load | 100 | % |


Instantaneous Renewable Output Percentage of Total Generation



Instantaneous Renewable Output Percentage of Total Load



100% Minus Instantaneous Nonrenewable Output as Percentage of Total Load





Compare Economics

IRR (%):5.42


Discounted payback (yr):11.8

Simple payback (yr):11.8


| 2 1 10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | Base Case | Current System |
|--|----------------|----------------|
| Net Present Cost | ₹463,674 | ₹362,159 |
| CAPEX | ₹0.00 | ₹600,000 |
| OPEX | ₹29,200 | -₹14,978 |
| LCOE (per kWh) | ▲ ₹8.00 | ₹1.27 |
| CO2 Emitted (kg/yr) | 2,307 | 1,113 |
| Fuel Consumption (L/yr) | 0 | 0 |




Current Annual Nominal Cash Flows



Base Case Annual Nominal Cash Flows



Cumulative Discounted Cash Flows





Such results are simulated in HOMER for all possible cases. The result of LCOE for different capacity with sensitivity variables discount rate, inflation rate are presented in Table 4.2.

Table 4.2: Levelized cost of energy (LCOE) for case-I

| | | _ | | | | | 5kW | P | V+ Gri | d- | LCOE | | | | | | | _ | |
|------------|------|---|--------|----|----------|----|--------|-----|--------|-----|---------|---|--------|---|--------|---|----------|----|--------|
| Sellback | Rate | 1 | | R | s.2.8/kV | Vh | | 1 | | F | ks.3/kW | h | | ı | | R | s.3.2/kV | Vh | |
| Inflation | Rate | ı | | ı | | ı | | ı | | ı | | 1 | | ı | | ı | | ı | |
| Discount | Rate | ı | 0% | 1 | 2% | 1 | 4% | 1 | 0% | 1 | 2% | ı | 4% | ١ | 0% | 1 | 2% | 1 | 4% |
| 0% | | 1 | 1.731 | 1 | 1.3829 | 1 | 1.0545 | 1 | 1.6043 | ı | 1.2561 | ī | 0.9277 | ı | 1.4775 | 1 | 1.1293 | 1 | 0.801 |
| 4% | | 1 | 2.4898 | 1 | 2.093 | 1 | 1.731 | 1 | 2.363 | ī | 1.9662 | ı | 1.6043 | 1 | 2.2362 | 1 | 1.8394 | Ī | 1.4775 |
| 6% | | 1 | 2.9029 | 1 | 2.4741 | 1 | 2.0858 | 1 | 2.7762 | ı | 2.3473 | 1 | 1.9591 | 1 | 2.6494 | 1 | 2.2205 | Ī | 1.8323 |
| 8% | | 1 | 3.3413 | ١ | 2.8779 | 1 | 2.459 | 1 | 3.2145 | 1 | 2.7512 | 1 | 2.3322 | 1 | 3.0878 | 1 | 2.6244 | 1 | 2.2055 |
| | | | | | | | 7.5kV | V I | PV+ Gr | id | LCOE | | | | | | | | |
| Sellback 1 | Rate | 1 | | R | s.2.8/kV | ۷h | | 1 | | F | ts.3/kW | h | | 1 | | R | s.3.2/kV | Vh | |
| Inflation | Rate | 1 | | ı | | ī | | 1 | | 1 | | 1 | | ı | | j | | 1 | |
| Discount | Rate | 1 | 0% | 1 | 2% | 1 | 4% | ١ | 0% | 1 | 2% | 1 | 4% | 1 | 0% | ١ | 2% | 1 | 4% |
| 0% | | 1 | 1.1159 | 1 | 0.7427 | 1 | 0.3908 | ١ | 0.9682 | 1 | 0.5951 | 1 | 0.2431 | ١ | 0.8205 | 1 | 0.4474 | 1 | 0.0955 |
| 4% | | ı | 1.9291 | 1 | 1.5038 | 1 | 1.1159 | 1 | 1.7814 | 1 | 1.3561 | 1 | 0.9682 | 1 | 1.6337 | 1 | 1.2084 | ١ | 0.8205 |
| 6% | | 1 | 2.3719 | ı | 1.9123 | 1 | 1.4962 | ì | 2.2242 | ١ | 1.7646 | 1 | 1.3485 | 1 | 2.0765 | ١ | 1.6169 | Ī | 1.2008 |
| 8% | | 1 | 2.8418 | 1 | 2.3451 | 1 | 1.8961 | ı | 2.6941 | ı | 2.1974 | Ī | 1.7484 | 1 | 2.5464 | 1 | 2.0497 | ١ | 1.6008 |
| | | | | | | | 10kW | 7 [| V+ Gri | id- | LCOE | | | | | | | | |
| Sellback l | Rate | 1 | | Rs | .2.8/kV | /h | | ١ | | F | ls.3/kW | h | | 1 | | R | s.3.2/kV | ۷h | |
| Inflation | Rate | Ī | | 1 | | ı | | ī | | ı | | ī | | ı | | ı | | ı | |
| Discount | Rate | 1 | 0% | 1 | 2% | 1 | 4% | Ţ | 0% | 1 | 2% | ŀ | 4% | 1 | 0% | 1 | 2% | 1 | 4% |
| 0% | | 1 | 0.7802 | 1 | 0.3937 | 1 | 0.0292 | ī | 0.6209 | Ī | 0.2344 | ī | | Ī | 0.4615 | Ī | 0.075 | Ī | - |
| 4% | | 1 | 1.6225 | 1 | 1.182 | 1 | 0.7802 | 1 | 1.4631 | 1 | 1.0226 | Ī | 0.υ209 | 1 | 1.3038 | Ī | 0.8633 | 1 | 0.4615 |
| 6% | | 1 | 2.0811 | 1 | 1.6051 | 1 | 1.1741 | i | 1.9218 | 1 | 1.4457 | Ī | 1.0147 | 1 | 1.7624 | 1 | 1.2863 | 1 | 0.8554 |
| 8% | | 1 | 2.5678 | 1 | 2.0534 | 1 | 1.5884 | Ī | 2.4084 | 1 | 1.894 | 1 | 1.429 | Ĩ | 2.2491 | 1 | 1.7347 | 1 | 1.2696 |

Discussion: The simulated result reported in Table.4.2, shows that, LCOE decreases with increase in, sellback rate and inflation rate. LCOE increase with increase in discount rate. As solar PV capacity increases, similar trend is observed, but LCOE is decreases with decreases in solar PV capacity. This increases capital, operation and maintenance cost of the system. Increase in solar PV rating, increases share of renewable energy. Now government is buying renewable energy at Rs.2.80/unit or kWh. If government or electricity boards increase sell back rate, then investment in solar rooftop by residential consumer start increasing.

The result of RCI, IRR and PBP for different capacity with sensitivity variable sell back rate are presented in Table 4.3.

Discussion: Calculated values of ROI and IRR increase with increases in rating of solar PV and increase with sell back rate. But these indices have no effect of inflation

Table 4.3: ROI, IRR and PBP for different configuration and sell back rate case-I

| Sellback Rate | I | R | s.: | 2.8/1 | ۲V | Vh | | | Rs | .3/k | W | h | Ī | R | s. | 3.2/1 | ςV | /h |
|---------------|---|-----|-----|-------|----|-------|---|-----|----|------|---|-------|---|-----|----|-------|----|-------|
| | Ī | ROI | Ī | IRR | Ī | PBP | Ī | ROI | | IRR | Ī | PBP | | ROI | | IRR | Ī | PBP. |
| Configuration | | (%) | | (%) | | (yrs) | | (%) | | (%) | | (yrs) | | (%) | | (%) | | (yrs) |
| 5kW PV+Grid | Ī | 4 | 1 | 6.1 | | 11.14 | 1 | 4.4 | | 6.7 | I | 10.64 | Ī | 4.8 | 1 | 7.3 | Ī | 10.18 |
| 7.5kW PV+Grid | | 3 | Ī | 4.8 | - | 12.46 | | | Ī | 5.4 | | 11.78 | Ī | 3.9 | 1 | 6.1 | T | 11.18 |
| 10kW PV+Grid | I | 2.5 | 1 | 4 | | 13.28 | 1 | 3 | | 4.7 | | 12.49 | Ī | 3.5 | 1 | 5.4 | 1 | 11.79 |

and discount rate. PBP calculations also shows that it increases with solar PV capacity and decreases with sell back rate. Hence LCOE index is better indication of economic evaluation along with PBP.

The result of CO2 emission for different capacity of solar PV are presented in Table 4.4.

Table 4.4: CO2 emission for different capacity of solar PV

| | CO2 emission | n reduction in CO2 |
|---------------|--------------|----------------------|
| Configuration | (kg/yr) | (%) |
| Grid | 2306.8 | <u> </u> |
| 5kW PV+Grid | 1181.617 | 1 48.78 |
| 7.5kW PV+Grid | 1139.517 | 50.60 |
| 10kW PV+Grid | 1113.407 | 51.73 |

Discussion: The result shows that CO2 emission decreases with increase in capacity of solar PV. It has no effect of inflation rate, discount rate and sell back rate. Almost 50% reduction in CO2 emission is reported with installation of solar PV at residential consumer.

4.4 Result: Case-II Commercial Project

After inputting data to HOMER software, simulation is carried out for different situations given in Table 4.5 Different cases for which simulations are acrried out Y: Feasible N: Not Feasible


Table 4.5: Different cases for which simulations are carried out Y: Feasible N: Not Feasible

| Ī | | Cor | ıfigu | ra | tion: | 2 | 5kW | , I | PV+ | Grid | | | _ | | | |
|----------------|--|------------|-------|-----|-------|----|------|-----|-----------------|------|-----|----|------|-----|-----|------|
| Sellback Rate | l | Rs. | 2.8/1 | ٠V | /h | ī | r | ls. | 3/k | Wh | ١ | R | s.3. | 2/k | 17. | li |
| Inflation Rate | ı | ı | | ī | | ī | | ı | | ī | 1 | | 1 | | ı | |
| Discount Rate | 09 | % I | 2% | ١ | 4% | ١ | 0% | ı | 2% | 1 4% | 1 | 0% | 1.2 | 2% | i | 4% I |
| l 0% | 3 | 7 | Y | 1 | Y | ī | Y | I | Y | Y | ١ | Y | ī | Y | 1 | Y |
| l 4% | 1 3 | <u> </u> | Y | 1 | Y | Ī | Y | Ī | Y | l Y | ١ | Y | Ī | Y | 1 | Y |
| 6% | 1) | <u>′ </u> | Y | ī | Y | 1 | Y | Ī | Y | ΙY | 1 | Y | I | Y | I | ΥI |
| l8% | 1 3 | <u> </u> | Y | 1 | Y | ! | Y | ī | Y | Y | I | Y | T | Y | 1 | ΥI |
| [| | Cor | ıfigu | ra | ion: | 5 | 0kW | 7 F | PV+ | Grid | | | | | | - 1 |
| Sellback Rate | | Rs. | 2.8/1 | ۲V | /h | Ī | F | ks. | 3/k | Wh | - | R | s.3. | 2/k | W | h |
| Inflation Rate | ! | i | | 1 | | Ī | | 1 | | 1 | ı | | 1 | | 1 | I |
| Discount Rate | 09 | % I | 2% | ١ | 4% | İ | 0% | Ī | 2% | 4% | 1 | 0% | 1.2 | 2% | 1 | 4% I |
| 0% | l Y | <u>'</u> | Y | 1 | Y | 1 | Y | 1 | Y | Y | ١ | Y | 1_ | Y | i | ΥI |
| i4% | l Y | 1 | Y | 1 | Y | 1 | Y | 1 | Υ | ΙY | -1 | Y | T | Y | I | ΥI |
| l6% | l Y | 1 | Y | Ī | Y | I | Y | ų. | Y | ΙY | ١ | Ÿ | T | Y | 1 | Ϋ́Ι |
| 8% | ΙY | <u> </u> | Y | Ī | Y | ī | Y | I | Y | l Y | ١ | Y | ! | Y | I | Y |
| · · | <u>. </u> | Cor | figu | ral | ion: | 7 | 5kW | F | ² V+ | Grid | | | | | | I |
| Sellback Rate | | Rs. | 2.8/1 | ιV | /h | 1 | · F | ls. | 3/k | Wh | - | R | s.3. | 2/k | W | h |
| Inflation Rate | <u> </u> | - 1 | | ī | | ı | | Ţ | | 1 | ١ | | ŀ | | 1 | |
| Discount Rate | 09 | 8 1 | 2% | ١ | 4% | i | 0% | I | 2% | 1 4% | 1 | 0% | 1 2 | 2% | 1 | 4% I |
| l 0% | ΙY | 1 | Y | ī | Y | 1 | Y | 1 | Y | l Y | Ī | Y | ı | Y | I | ΥI |
| 4% | ΙY | 1 | Y | Ī | Y | Ī | Y | i | Y | ΙY | 1 | Y | 1 | Y | ī | ΥI |
| l 6% | l V | 1 | Y | 1 | Y | 1 | Y | I | Y | Y | | Y | ı | Y | ī | ΥI |
| l8% | Y | 1 | Y | 1 | Y | 1 | Y | I | Y | Y | 1 | Y | 1 | Y | I | Y |
| | (| Con | figur | at | ion: | 10 | 00kV | 7 1 | PV+ | Gric | | | | | | |
| Sellback Rate | | Rs. | 2.8/k | V | /h | I | F | ls. | 3/k\ | Wh | Ī | R | s.3. | 2/k | W | h |
| Inflation Rate | ļ | I | | 1 | | ١ | | ï | | 1 | Ī | | 1 | | ī | |
| Discount Rate | 09 | 6 I | 2% | 1 | 4% | 1 | 0% | ľ | 2% | 1 4% | - 1 | 0% | 1 2 | 2% | L | 4% I |
| υ% | N | | N | 1 | N | 1 | Y | I | Y | l N | Ī | Y | 1 | Υ | Ī | N |
| 4% | N | <u> </u> | N | 1 | N | Ī | Y | ١ | Y | ΙY | Ī | Y | I | Y | Ī | Y |
| 6% | <u> </u> | · 1 | N | 1 | N | 1 | Y | 1 | Y | ΙY | Ī | Y | 1 | Y | Ī | Υ |
| l8% | N | | N | 1 | N | 1 | Y | Ī | Y | l Y | 1 | Y | Ī | Y | Ī | ΥI |

The simulation result report generated by HOMER for 10kW PV+Grid, Discount Rate=8%, Inflation Rate=4%, Sellback rate=Rs.3.2 kWh is given below.



System Simulation Report



File: Commercial.homer

Author: Ganesh N. Jadhav

Location: K.K. Wagh Building, Mumbai Agra Rd, Durga Nagar, Nashik, Maharashtra

422006, India (20°0.8'N, 73°49.4'E)

Total Net Present Cost: ₹7,296,096.00

Levelized Cost of Energy (₹/kWh): ₹2.75

Notes:

Sensitivity variable values for this simulation

| Variable | Value | | | Unit |
|-----------------------|-------|--------------|-------|------------------|
| Diesel Fuel Price | 100 | The William | | OIIIC E Į₹/Ls |
| Sellback Rate | 3.00 | | | ₹/kWh |
| ExpectedInflationRate | 4.00 | ALIEN PARTIE | | 9/0 |
| Nomina DiscountRate | 6.00 | A | 7 4 0 | % |




Table of Contents

| ANY NO. | |
|---------------------------|-----|
| Cost Summary | 3 |
| Cash Flow | 4 |
| System Architecture | . 5 |
| Electrical Summary | 6 |
| PV: Generic flat plate PV | 7 |
| Grid: Grid | 8 |
| Renewable Summary | 10 |
| Compare Economics | 11 |



Cost Summary



Net Present Costs


| Name | Capital | Operating | Replacement | Salvage | Resource | Total |
|--------------|---------|-----------|-------------|---------|----------|---------|
| Generic flat | 7 | | | | | |
| plate PV | ₹4.13M | ₹8.13M | ₹2.82M | -₹1.92M | ₹0,00 | ₹13.1M |
| Grid | ₹0.00 | -₹5.85M | ₹0.00 | ₹0.00 | ₹0.00 | -₹5.85M |
| System | ₹4.13M | ₹2.27M | ₹2.82M | -₹1.92M | ₹0.00 | ₹7.30M |

Annualized Costs

| Name | Capital - | - Operating | Replacement | Sa vage | Resource - | Total |
|--------------|-----------|-------------|-------------|----------|------------|-----------|
| Generic flat | | | | 63 | | |
| plate PV | ₹209,381 | ₹412,500 | ₹143.050 | -₹97.541 | ₹0.00 | ₹667.390 |
| Grid | ₹0.00 | -₹297,C47 | ₹0.00 | ₹0.00 | ₹0.00 | -₹297.047 |
| System | ₹209,381 | ₹115,453 | ₹143,050 | ₹97,541 | ₹0.00 | ₹370.343 |



Cash Flow





System Architecture

| Component | Name | Size | Unit |
|-------------------|-----------------------|------|------|
| PV | Generic flat plate PV | 75.0 | kW |
| Grid | Grid | 200 | kW |
| Dispatch strategy | HOMER Cycle Charging | | |

Schematic





Electrical Summary

Excess and unmet

| Quantity | Value | Units |
|---------------------|-------|--------|
| Excess Electricity | 0 | kWh/yr |
| Unmet Electric Load | 0 | kWh/yr |
| Capacity Shortage | 0 | kWh/yr |

Production Summary

| Component | Production (kWh/yr) | Percent |
|-----------------------|---------------------|---------|
| Generic flat plate PV | 128,216 | 95,3 |
| Grid Purchases | 6,289 | 4.68 |
| Total | 134,505 | 100 |

Consumption Summary

| Component | Consumption (kWh/yr) | Percent |
|-----------------|----------------------|---------|
| AC Primary Load | 29,200 | 21.7 |
| DC Primary Load | 0 | 0 |
| Deferrable Load | 0 | 0 |
| Grid Sales | 105,305 | 78.3 |
| Total | 134,505 | 100 |



PV: Generic flat plate PV


Generic flat plate PV Electrical Summary

| Quantity | Value | Units | |
|--------------------|-------|--------|--------------|
| Minimum Output | 0 | kW | |
| Maximum Output | 79.8 | kW | |
| PV Penetration | 439 | % | |
| Hours of Operation | 4,407 | hrs/yr | |
| Levelized Cost | 5.21 | ₹/kWh | and the same |

Generic flat plate PV Statistics

| Quantity | Value | Units |
|------------------|---------|--------|
| Rated Capacity | 75.0 | kW |
| Mean Output | 14.6 | kW |
| Mean Output | 351 | kWh/d |
| Capacity Factor | 19.5 | % |
| Total Production | 128,216 | kWh/yr |

Generic flat plate PV Output (kW)





Grid: Grid

Grid rate: Demand 1

| Month | Energy Purchased (kWh) | Energy Sold (kWh) | Net Energy Purchased (kWh) | Peak Demand (kW) | Energy Charge | Demand Charge |
|-----------|------------------------------|----------------------|----------------------------------|---------------------|---------------|------------------|
| January | 0 | 0. | 0 | 8.07 | ₹0.00 | ₹0.00 |
| February | 0 | 0 | 0 | 6.88 | ₹0.00 | ₹0.00 |
| March | 0 | 0 | 0 | 5.72 | ₹0.00 | ₹0.00 |
| April | 0 / | 0 | 0 | 4.91 | ₹0.00 | ₹0.00 |
| May | 0 | 0 | 0 | 4,78 | ₹0,00 | ₹0,00 |
| June | 0 | 0 | 0 | 5.23 | ₹0.00 | ₹0.00 |
| July | 0 | 0/ | 0 | 5.31 | ₹0.00 | ₹0.00 |
| August | 0 | 0/ | 0 | 6.27 | ₹0.00 | ₹0.00 |
| September | 0 | 0 | 0 | 7.91 | ₹0.00 | ₹0.00 |
| October | ٥ | // O | 0 | 6.23 | ₹0.00 | ₹0.00 |
| November | 0 | 0 | 0 | 7,59 | ₹0,00 | ₹0.00 |
| December | 0 | 0 | 0 | 7.12 | ₹0.00 | ₹0.00 |
| Annual | 0 | 0 | 0 | 8.07 | ₹0.00 | ₹0.00 |

Grid rate: Rate 1


| Month | Energy Purchased (kWh) | Energy Sold (kWh) | Net Energy Purchased (kWh) _ | Peak Demand (kW) | Energy Charge | Demand Charge |
|-----------|------------------------------|----------------------|------------------------------------|---------------------|---------------|------------------|
| January | 710 | 10,527 | -9,816 | 0 | ₹0.00 | ₹0.00 |
| February | 546 | 9,739 | -9.192 | 0 | ₹0.00 | ₹0.00 |
| March | 555 | 10,518 | -9,963 | Ŋ | ₹0,00 | ₹0,00 |
| April | 459 | 10,098 | -9,639 | 10 | ₹0.00 | ₹0.00 |
| May | 380 | 10,431 | -10,052 | 0 | ₹0.00 | ₹0.00 |
| June | 383 | 7,498 | -7,116 | 0 | ₹0.00 | ₹0.00 |
| July | 381 | 5,706 | -5,325 | 0.0 | ₹0.00 | ₹0.00 |
| August | 466 | 5,280 | -4,814 | 0 | ₹0,00 | ₹0.00 |
| September | 498 | 6,688 | -6,190 | 0 | ₹0,00 | ₹0.00 |
| October | 573 | 9,118 | -8,545 | 0 . | ₹0.00 | ₹0.00 |
| November | 635 | 9,666 | -9.031 | 0 | ₹0.00 | ₹0.00 |
| December | 703 | 10,036 | -9,332 | 0 | ₹0.00 | ₹0.00 |
| Aiinual | 6,289 | 105,305 | -99,016 | 0 | -₹297,047 | ₹0.00 |

Grid rate: All


| | | | | A. A. Carrier and St. Carrier | | |
|---------------|------------------------------|------------------------------|------------------------------------|---|---------------|------------------------|
| ™ onth | Energy Purchased (kWh) | Energy <u>S</u> old (RWh) | Net Energy - Purchased (kWh) | Peak Demand (kW) | Energy Charge | - -Demand Charge |
| January | 710 | 10,527 | -9,816 | 8.07 | ₹0.00 | ₹0,00 |
| February | 546 | 9,739 | -9,192 | 6.88 | ₹0.00 | ₹0.00 |
| March | 555 | 10,518 | -9,963 | 5.72 | ₹0.00 | ₹0.00 |
| April | 459 | 10,098 | -9,639 | 4.91 | ₹0.00 | ₹0.00 |
| May | 380 | 10,431 | -10,052 | 4.78 | ₹0.00 | ₹0.00 |
| June | 383 | 7,498 | -7,116 | 5.23 | ₹0.00 | ₹0.00 |
| July | 381 | 5,706 | -5,325 | 5.31 | ₹0.00 | ₹0.00 |
| August | 466 | 5,280 | -4,814 | 6.27 | ₹0.00 | ₹0.00 |
| September | 498 | 6,688 | -6,190 | 7.91 | ₹0.00 | ₹0.00 |
| October | 573 | 9,118 | -8,545 | 6.23 | ₹0,00 | ₹∪.00 |
| November | 635 | 9,666 | -9,031 | 7.59 | ₹0,00 | ₹0.00 |
| December | 703 | 10,036 | -9,332 | 7.12 | ₹0,00 | ₹0.00 |
| Annual | 6,289 | 105,305 | -99,016 | 8.07 | -₹297,047 | ₹0,00 |



Energy Purchased From Grid (kW)



Energy Sold To Grid (kW)







Renewable Summary

| Capacity-based metrics | Value | Unit |
|--|-------|------|
| Nominal renewable capacity divided by total nominal capacity | 100 | % |
| Usable renewable capacity divided by total capacity | 100 | % |
| Energy-based metrics | Value | Unit |
| Total renewable production divided by load | 95,3 | % |
| Total renewable production divided by generation | 95.3 | % |
| One minus total nonrenewable production divided by load | 100 | % |
| Peak values | Value | Unit |
| Renewable output divided by load (HOMER standard) | 100 | % |
| Renewable output divided by total generation | 100 | % |
| One minus nonrenewable output divided by total load | 100 | % |


Instantaneous Renewable Output Percentage of Total Generation



Instantaneous Renewable Output Percentage of Total Load



100% Minus Instantaneous Nonrenewable Output as Percentage of Total Load





Compare Economics

IRR (%):3.38


Discounted payback (yr):N/A

Simple payback (yr):14.1


| | Base Case | Current System |
|-------------------------|-----------|-----------------|
| Net Present Cost | ₹8.05M | ₹7 . 30M |
| CAPEX | ₹0.00 | ₹4.13M |
| OPEX | ₹408,800 | ₹160,962 |
| LCOE (per kWh) | ₹14.00 | ₹2.75 |
| CO2 Emitted (kg/yr) | 18,454 | 3,975 |
| Fuel Consumption (L/yr) | 0 | 0 |




Current Annual Nominal Cash Flows



Base Case Annual Nominal Cash Flows



Cumulative Discounted Cash Flows



Such results are simulated in HOMER for all possible cases. The result of LCOE for different capacity with sensitivity variables discount rate, inflation rate are presented in Table 4.6.

Table 4.6: Levelized cost of energy (LCOE) for case-II

| | 25kW PV+ Grid- LCOE | | | | | | | | | | | | | | | | |
|----------------------|---------------------|-----|------------|---|----------|----|----------|----|----------|---|----------|---|----------|---|------------|---|----------|
| Sellback Rate | l | | Rs.2.8/kWl | h | | ī | | | Rs.3/kWh | , | | ī | | 1 | Rs.3.2/kWl | ı | |
| Inflation Rate | l | ı | | ı | | ī | | 1 | | ī | | 1 | | ī | | ī | |
| Discount Rate | 0% | 1 | 2% | ı | 4% | ı | 0% | 1 | 2% | ı | 4% | ı | 0% | 1 | 2% | ı | 4% |
| 0% | l 3.276141 | 1 | 2.966496 | ١ | 2.674475 | ı | 3.223445 | i | 2.913801 | ī | 2.621779 | ı | 3.17075 | ı | 2.861105 | ī | 2.569084 |
| 4% | 3.950933 | - 1 | 3.598011 | 1 | 3.276141 | 1 | 3.898237 | ı | 3.545316 | ī | 3.223445 | Ī | 3.845542 | I | 3.49262 | ı | 3.17075 |
| 6% | 4.318361 | Ī | 3.936969 | ١ | 3.591673 | ı | 4.265666 | ı | 3.884274 | ı | 3.538978 | i | 4.21297 | 1 | 3.831578 | ī | 3.486283 |
| 8% | 1 4.708247 | 1 | 4.296131 | 1 | 3.923573 | Ī | 4.655552 | ī | 4.243435 | 1 | 3.870877 | ı | 4.602856 | 1 | 4.19074 | ī | 3.818182 |
| | | | | | 50 |)k | W PV+ Gr | ic | - LCOE | | | | | | | | - |
| Sellback Rate | 1 | 1 | Rs.2.8/kWl | h | | 1 | | | Rs.3/kWh | ı | | ī | | 1 | Rs.3.2/kWl | 1 | |
| Inflation Rate | ı | ı | | ī | | 1 | | ī | | 1 | | ı | | 1 | | ı | |
| Discount Rate | 1 0% | 1 | 2% | ı | 4% | ı | 0% | ı | 2% | ı | 4% | 1 | 0% | 1 | 2% | ı | 4% |
| 0% | 1 2.760996 | ı | 2.416345 | Ī | 2.091311 | ī | 2.639092 | ı | 2.294441 | i | 1.969407 | ı | 2.517188 | 1 | 2.172538 | 1 | 1.847503 |
| 4% | 3.512074 | 1 | 3.119254 | r | 2.760996 | ī | 3.39017 | ı | 2.99735 | ı | 2.639092 | ı | 3.268266 | 1 | 2.875446 | ı | 2.517188 |
| 6% | l 3.92104 | 1 | 3.490531 | Ī | 3.112199 | ī | 3.799136 | 1 | 3.374627 | ı | 2.990295 | ı | 3.677232 | 1 | 3.252723 | ī | 2.068392 |
| 8% | l 4.3550∩2 | ı | 3.896296 | ١ | 3.48162 | ı | 4.233099 | ı | 3.774393 | ī | 3.359716 | ī | 4.111195 | ı | 3.652489 | ī | 3.237813 |
| | | | | | 75 | k' | W PV+ Gr | ic | i- LCOE | | | | | | | | |
| Sellback Rate | <u> </u> | 1 | Rs.2.8/kWl | 1 | | ī | | | Rs.3/kWh | | | ı | | 1 | Rs.3.2/kWl | 1 | |
| Inflation Rate | 1 | ı | | ı | | 1 | | ı | | ī | | ı | | ī | | Í | |
| Discount Rate | ı 0% | 1 | 2% | ١ | 4% | ı | 0% | ı | 2% | ı | 4% | ı | 0% | ı | 2% | ı | 4% |
| 0% | 1 2.538989 | 1 | 2.184112 | Ī | 1.849434 | ! | 2.391759 | ī | 2.036882 | ī | 1.702204 | Ī | 2.244529 | ı | 1.689652 | 1 | 1.554973 |
| 4% | I 3.312352 | ı | 2.907877 | I | 2.538989 | ı | 3.165122 | 1 | 2.760647 | ı | 2.391759 | ı | 3.017892 | ī | 2.613417 | ı | 2.244529 |
| 6% | 1 3.703454 | 1 | 3.296349 | ī | 2.900613 | ! | 3.586223 | ı | 3.149118 | 1 | 2.753383 | ı | 3.438993 | i | 3.001888 | ī | 2.606153 |
| 8% | 1 4.180293 | Ī | 3.707976 | 1 | 3.280996 | 1 | 4.033062 | ı | 3.560716 | 1 | 3.133765 | ī | 3.885832 | ī | 3.413516 | ı | 2.986535 |
| 100kW PV+ Grid- LCOE | | | | | | | | | | | | | | | | | |
| Sellback Rate | 1 | I | ks.2.8/kWh | 1 | | Ī | | | Rs.3/kWh | ı | | Ī | | I | Rs.3.2/kWh | , | |
| Inflation Rate | ŀ | 1 | | ı | | ı | | ı | | ī | | ı | | ī | | 1 | |
| Discount Rate | ı 0% | 1 | 2% | 1 | 4% | ı | 0% | ı | 2% | 1 | 4% | 1 | 0% | 1 | 2% | 1 | 4% |
| 0% | 2.419138 | 1 | 2.059487 | 1 | 1.720306 | ı | 2.258927 | ļ | 1.899276 | ī | 1.560094 | ı | 2.098715 | ١ | 1.739064 | 1 | 1.399883 |
| 4% | 3.202907 | 1 | 2.79299 | ı | 2.419138 | Ī | 3.042695 | ı | 2.632778 | ī | 2.258927 | ı | 2.882483 | ı | 2.472566 | ı | 2.098715 |
| 6% | 3.629673 | ı | 3.186687 | ı | 2.785628 | ī | 3.469461 | ı | 3.026476 | ١ | 2.625417 | ı | 3.30925 | ı | 2.866264 | ı | 2.465205 |
| 8% | 4.082524 | ı | 3.603853 | ī | 3.171128 | ı | 3.922312 | ı | 3.443641 | ī | 3.010916 | ı | 3.7621 | ı | 3.283429 | ī | 2.850705 |

Discussion: The simulated result reported in Table.4.6, shows that, LCOE decreases with increase in, sellback rate and inflation rate. LCOE increase with increase in discount rate. As solar PV capacity increases, similar trend is observed, but LCOE is decreases with decreases in solar PV capacity. This increases capital, operation and maintenance cost of the system. Increase in solar PV rating, increases share of renewable energy.

Now government is buying renewable energy at Rs.2.80/unit or kWh. If government or electricity boards increase sell back rate, then investment in solar rooftop by commercial consumer start increasing. The result also shows that LCOE can not be calculated for 100kW solar PV capacity with sell back rate of Rs.2.8/kWh.

The result of ROI, IRR and PBP for different capacity with sensitivity variable sell back rate are presented in Table 4.7.

Table 4.7: ROI, IRR and PBP for different configuration and sell back rate case-II

| Sellback Rate | | Rs.2 | 2.8/k | (W | h | 1 |] | Rs. | 3/k | Wh | | | R | s.3 | .2/1 | ςW | 'h |
|---------------------|-----|------|-------|----|------|---|------|-----|------------------|----|------|---|------|-----|------|----|-------|
| 1 | | ROI | IRR | F | PBP | I | ROI | I | RR | I | PBP | | ROI | ΙI | RR | 1 | PBP |
| Configuration | | (%) | (%) | (| yrs) | | (%) |] (| (%) | (| yrs) | ! | (%) | (| (%) | 1 | (yrs) |
| <u>25kW PV+Grid</u> | 1: | 17.5 | 22 | 4 | 1.45 | Ī | 17.7 | 2 | 22.2 | 4 | 4.41 | Ī | 17.9 | 12 | 22.5 | 1 | 1.37 |
| 50kW PV+Grid | _ | 5.6 | 8.3 | 5 | 9.44 | 1 | 6 | 1 | 8.9 | (| 9.09 | Ī | 6.4 | 1 | 9.4 | 1 | 8.76 |
| 75kW PV+Grid | | 1.6 | 2.6 | 1 | 5.08 | I | 2.1 | T | $\overline{3.4}$ | 1 | 4.06 | 1 | 2.6 | 1 | 4.1 | 1: | 13.17 |
| 100kW PV+Grid | 1 - | -0.4 | _ | | | Ī | 0.2 | 1 | 0.3 | 2 | 4.95 | Ī | 0.7 | | 1.1 | 1 | 17.6 |

Discussion: Calculated values of ROI and IRR increase with increases in rating of solar PV and increase with sell back rate. But these indices have no effect of inflation and discount rate. PBP calculations also shows that it increases with solar PV capacity and decreases with sell back rate. Hence LCOE index is better indication of economic evaluation along with PBP. Calculation of ROI, IPR and PBP is infeasible for 100kW solar PV capacity with Rs.2.80/kWh sell back rate.

The result of CO2 emission for different capacity of solar PV are presented in Table 4.8.

Discussion: The result shows that CO2 emission decreases with increase in capacity of solar PV. It has no effect of inflation rate, discount rate and sell back rate. Almost 70 to 80% reduction in CO2 emission is reported with installation of solar PV at commercial

Table 4.8: CO2 emission for different capacity of solar PV

| | CO2 emission | reduction in CO2 |
|---------------|--------------|------------------|
| Configuration | (kg/yr) | (%) |
| Grid | 18454.4 | - |
| 25kW PV+Grid | 5464.047 | 70.39 |
| 50kW PV+Grid | 4331.269 | 76.53 |
| 75kW PV+Grid | 3974.609 | 78.46 |
| 100kW PV+Grid | 3794.834 | 79.44 |

consumer.

As per scheme of grid solar rooftop PV launched by Ministry of New and Renewable energy, Government of India,30% subsidy on capital cost is given to project. With this subsidy, LCOE and PBP will further reduced.

Chapter 5

Conclusion

The method of Levelized Cost of Electricity (LCOE) allows a comparison of power plants with different generating and cost structures. The LCOE results from the comparison of all costs, which arise throughout the lifetime of the power plant for the construction and operating of the plant, with the sum of the generated amount of energy throughout the life cycle. The underlying idea is that the generated electricity implicitly corresponds to the revenue from the sale of this energy. Thus, the further this income is in the future, the lower the associated present value.

The LCOE represents a comparative calculation on a cost basis and not a calculation of feed-in tariffs. These can only be calculated by adding further influencing parameters. As calculation of LCOE does not take into account the value of the electricity produced within an energy system in a given hour of the year, it is to be emphasized that this method is an abstraction of reality aiming at making different power plants comparable. The method is not suitable for determining the profitability of a specific plant. For this purpose, a financial calculations, which takes into account all income and expenditure

with a cash flow model must be carried out.

The LCOE can be used to support decision-making. It should be noted that the LCOE is a cost-based figure and does not include revenues.

References

- "National electricity plan," Government of India, Ministry of Power, CEA, Tech.
 Rep., Jan 2018.
- [2] "Guidelines on implementation of phase ii of grid connected rooftop solar programme for achieving 40 gw capacity from rooftop solar by the year 2022," Govenment of India, Ministry of New and Renewable Energy, Tech. Rep., Aug 2019.
- [3] A. Ipakchi and F. Albuyeh, "Grid of the future," *IEEE Power and Energy Magazine*, vol. 7, no. 2, pp. 52–62, March 2009.
- [4] The Smart Grid: An Introduction. US Department of Energy, 2009.
- [5] H. Suyanto and R. Irawati, "Study trends and challenges of the development of microgrids," in 2017 15th International Conference on Quality in Research (QiR): International Symposium on Electrical and Computer Engineering, July 2017, pp. 383-387.
- [6] S. Parhizi, H. Lotfi, A. Khodaei, and S. Bahramirad, "State of the art in research on microgrids: A review," *IEEE Access*, vol. 3, pp. 890-925, 2015.

- [7] "IEEE approved draft guide to conducting distribution impact studies for distributed resource interconnection," *IEEE P1547.7/D11*, *June 2013*, pp. 1–129, Feb 2014.
- [8] D. Lee, J. Park, H. Shin, Y. Choi, H. Lee, and J. Choi, "Microgrid village design with renewable energy resources and its economic feasibility evaluation," in 2009 Transmission Distribution Conference Exposition: Asia and Pacific, Oct 2009, pp. 1–4.
- [9] W. Huang, G. Wang, W. Wang, Y. Sun, R. Wang, and D. Wang, "Research on integrated benefit evaluation model of microgrid," in 2012 China International Conference on Electricity Distribution, Sep. 2012, pp. 1–4.
- [10] X. Jin, "Analysis of microgrid comprehensive benefits and evaluation of its economy," in 10th International Conference on Advances in Power System Control, Operation Management (APSCOM 2015), Nov 2015, pp. 1-4.
- [11] "National electricity policy," Govt. of India, Ministry of New and Renewable Energy, Tech. Rep., March 2016.
- [12] J. Xiaoling, "Comprehensive benefits analysis and economic evaluation of microgrid," International Journal of Smart Grid and Clean Energy, vol. 4, no. 3, July 2015.
- [13] Su Wei-Fu, Huang Shyh-Jier, and Lin Chin-E., Economic analysis for demand-side hybrid photovoltaic and battery energy storage system," *IEEE Transactions on Industry Applications*, vol. 37, no. 1, pp. 171–177, Oct 2002.

- [14] A.P. Agalgaonkar, S.V. Kulkarni, and S.A. Khaparde, "Evaluation of configuration plans for dgs in developing countries using advanced planning techniques," *IEEE Transactions on Power Systems*, vol. 21, no. 2, pp. 973–981, May 2006.
- [15] P.M. Costa and M.A. Matos, "Economic analysis of microgrids including reliability aspects," in *International Conference on Probabilistic Methods Applied to Power Systems*, Stockholm, June 2006, pp. 1–8.
- [16] H. Asano and S. Bando, "Economic evaluation of microgrids," in IEEE Power and Energy Society General Meeting - Conversion and Delivery of Electrical Energy in the 21st Century, Pittsburgh, PA., July 2008, pp. 1–6.
- [17] G.Y. Morris and C. Abbey, "Evaluation of the costs and benefits of microgrids with consideration of services beyond energy supply," in *IEEE Power and Energy Society* General Meeting, San Diego, CA, July 2012, pp. 1–9.
- [18] F. Cucchiella and I. D'Adamo, "A photovoltaic system in a residential building: environmental and economic imization analysis," in 8th International Conference on Supply Chain Management and Information Systems(SCMIS), Hong Kong, Oct 2010, pp. 1–9.
- [19] Min-ho Suh, Kang-Hoe Kim, and Young Il Kwon, "Economic analysis of korean photovoltaic power generation project," in 8th International Conference on Information Science and Digital Content Technology, Jeju Island Korea, June 2012, pp. 340–343.

- [20] J. Nazarko and M. El-Saadawi, "Economic analysis of integrating photovoltaic plants with national egyptian utility," in 10th Mediterranean Electrotechnical Conference, 2000, May 2000, pp. 1161–1164.
- [21] Wajid Muneer, Kankar Bhattacharya, and Caizares. Claudio A, "Large-scale solar pv investment models, tools, and analysis: The ontario case," *IEEE Transactions* on Power Systems, vol. 26, no. 4, pp. 2547–2555, Nov 2011.
- [22] C. Lin, W. Hsieh, C. Chen, C. Hsu, T. Ku, and C. Tsai, "Financial analysis of a large-scale photovoltaic system and its impact on distribution feeders," *IEEE Transactions on Industry Applications*, vol. 47, no. 4, pp. 1884–1891, July 2011.
- [23] Changsong Chen and Shanxu Duan, "imal design and economic analysis of energy storage system in microgrids," *IEEE Transactions on Power Electronics*, vol. 26, no. 10, pp. 2762–2773, Oct 2011.
- [24] Chia-Hung Lin and Wei-Lin Hsieh, "Financial analysis of a large-scale photovoltaic system and its impact on distribution feeders," *IEEE Transactions on Industry* Applications, vol. 47, no. 4, pp. 1884–1891, July 2011.
- [25] M. Mao, P. Jin, L. Chang, and H. Xu, "Economic analysis and optimal design on microgrids with ss-pvs for industries," *IEEE Transactions on Sustainable Energy*, vol. 5, no. 4, pp. 1328–1336, Oct 2014.
- [26] T. E. Del Carpio Huayllas and D. S. Ramos, "Economic evaluation of a residential solar microgrid connected to the distribution system," in 2013 IEEE PES Confer-

- ence on Innovative Smart Grid Technologies (ISGT Latin America), April 2013, pp. 1–6.
- [27] H. Ritchie and M. Roser, "Renewable energy," Our World in Data, 2019, https://ourworldindata.org/renewable-energy.
- [28] "Executive summary power sector may 2018," Central Electricity Authority, Ministry of Power, Govt. of India, Tech. Rep., May 2018.
- [29] "Ministry of new and renewable energy, physical progress (achievements)," Ministry of New and Renewable Energy, Govt. of India, Tech. Rep., July 2018.